



# AGA CERTIFIED PRODUCT



Certificate Holder: **UNI-GERÄTE E. MANGELMANN ELEKTROTECHNISCHE FABRIK GmbH**

ABN/ACN No. (if applicable): **N/A**

Manufacturer: **UNI-GERÄTE E. Mangelmann Elektrotechnische Fabrik GmbH**

Agent (if applicable): **N/A**

Type of Component: **Direct Acting, Disc-On-Seat Automatic Shut-Off Valves, normally closed**

Model No. & Description: **UNI-GERÄTE VS/DVS Series**

**Models:**

**VS: VS05...00, VS07...00, VS10...00, VS05...S1, VS07...S1, VS10...S1, VS05N...00, VS07N...00, VS10N...00, VS05N...S1, VS07N...S1, VS10N...S1**  
**DVS: DVS05...00(M1), DVS07...00(M1), DVS10...00(M1), DVS05...S1M1, DVS07...S1M1, DVS10...S1M1, DVS05N...00(M1), DVS07N...00(M1), DVS10N...00(M1), DVS05N...S1M1, DVS07N...S1M1, DVS10N...S1M1**

**Class: 1**

**Connection: thread Connection G1/2", G3/4" and G1" or flange Connection DN15, DN20 and DN25**

**Ambient temperature range: -20°C - +60°C.**

**Pressure rating: 1000 kPa**

**Voltage: 24 V DC, 110 V DC/AC 40-60 Hz, 230V DC/AC 40-60 Hz**

Refer Specification info for more detail on model suffixes

(Refer [www.aga.asn.au](http://www.aga.asn.au) for more details)

Relevant Standard(s): **AS 4629-2005 (Inc. Amendment 1 & 2)**

This is to certify that the particular **COMPONENT** specifically described herein and supplied to The Australian Gas Association (hereafter called the AGA) by the Certificate Holder named above has been subject to "type-testing" and assessed by the AGA to comply with the requirements of the AGA's Product Certification Scheme for Type Tested Gas Products.

**This Certificate is issued on the express conditions that:**

- (i) The Certificate Holder undertakes to comply with the Rules Governing The AGA's Product Certification Scheme (hereafter called the Rules Governing);
- (ii) This Certificate remains the property of the AGA; and
- (iii) The AGA reserves the right to cancel this Certificate in accordance with the Rules Governing, and in such an event the Certificate Holder undertakes to surrender the Certificate to the AGA upon request.





**Client Manager**



**Certificate Authorised**

Certificate first issued: **12 July 2021**

Certificate No: **8953**

This copy valid from: **12 July 2021**

Refer specification issue: **01**